

Foundation for Cross-Connection Control and Hydraulic Research
University of Southern California
University Park
Los Angeles, California 90089

Testing laboratories other than the laboratory listed above will be added to an approved list as they are qualified by the Lebanon Utilities. Backflow preventers which may be subjected to backpressure or backsiphonage that have been fully tested and have been granted a Certificate of Approval by said qualified laboratory and are listed on the laboratory's current list of "Approved Backflow Prevention Assemblies" may be used without further test or qualification.

3.2.6. It shall be the duty of the customer-user at any premises where backflow prevention assemblies are installed to have certified inspections and operational tests made upon installation and at least once per year. In those instances where the Lebanon Utilities Water Department Superintendent deems the hazard to be great enough he may require certified inspections at more frequent intervals. These inspections and tests shall be at the expense of the water user and shall be performed by the assembly manufacturer's representative, Lebanon Utilities personnel or by a certified tester approved by the Lebanon Utilities. It shall be the duty of the Lebanon Utilities to see that these tests are made in a timely manner. The customer-user shall notify the Lebanon Utilities in advance when the tests are to be undertaken so that an official representative may witness the tests if so desired. These assemblies shall be repaired, overhauled or replaced at the expense of the customer-user whenever said assemblies are found to be defective. Records of such tests, repairs and overhaul shall be kept and made available to the Lebanon Utilities.

3.2.7. All presently installed backflow prevention assemblies which do not meet the requirements of this section but were approved devices for the purposes described herein at the time of installation and which have been properly maintained, shall, except for the inspection and maintenance requirements under subsection 3.2.6., be excluded from the requirements of these rules so long as the Lebanon Utilities is assured that they will satisfactorily protect the utility system. Whenever the existing device is moved from the present location or requires more than minimum maintenance or when the Lebanon Utilities finds that the maintenance constitutes a hazard to health, the unit shall be replaced by an approved backflow prevention assembly meeting the requirements of this section.

This ordinance shall be in full force and effect from and after its passage and any publication which may be required of the same by law.

ALL OF WHICH IS CONSIDERED, APPROVED AND ADOPTED BY THE COMMON COUNCIL OF THE CITY OF LEBANON, INDIANA, this 10th day of September, 1990

PRESIDING OFFICER:

Ann Garoffolo (signed)
Ann Garoffolo

ATTEST:

Helen M. Harman (signed)
Helen M. Harman, Clerk-Treasurer

Presented by me to the Mayor of the City of Lebanon, Indiana on this 10th day of September, 1990.

Helen M. Harman (signed)
Helen M. Harman, Clerk-Treasurer

EXAMINED, APPROVED AND SIGNED by me on the 10th day of September, 1990.

Ann Garoffolo (signed)
Ann Garoffolo, Mayor

ORDINANCE NO. 90-18

AN ORDINANCE AMENDING THE RESIDENTIAL SURCHARGE
FOR SOLID WASTE DISPOSAL

WHEREAS, the City of Lebanon, Indiana, has employed a private waste disposal service for the past several years and is currently under contract with an organization known as Waste Management Services, which contract has duration of three (3) years and expires on September 1, 1991, and pursuant to said contract, the initial cost of trash disposal per residential household in the city of Lebanon...