

8450 Westfield Blvd, Suite 300
Indianapolis, IN 46240
317.713.4615
bfsengr.com



INDIANAPOLIS | LAFAYETTE | MERRILLVILLE
FORT WAYNE | PLAINFIELD | SOUTH BEND | LOUISVILLE

March 20, 2023

Mr. Kevin Krulik, PE
City Engineer
City of Lebanon
One Municipal Plaza
401 South Meridian Street
Lebanon, IN 46052

RE: McClure Store Addition

Mr. Krulik:

On behalf of the Lebanon Utilities, we have completed the review of the subject project. We recommend the approval of the plans subject to the comments in the attached letter.

We appreciate the opportunity to review the subject project on behalf of the Lebanon Utilities. If you have any questions or concerns, please contact the undersigned.

Very truly yours,

BUTLER, FAIRMAN and SEUFERT, INC.

A handwritten signature in black ink, appearing to read "John Lightner".

John Lightner, PE
jlightner@bfsengr.com

The following comments are offered regarding the above referenced project:

Sanitary Sewer (Lebanon Utilities):

- 1. The proposed under-the-sink grease trap is acceptable based on comments at TAC by the Owner's Representative that the purpose of the kitchen area is for warming food rather than for food preparation. Should food preparation be contemplated in the future, a grease trap in accordance with the Lebanon City Standards will be required.*